



Nederlandse norm

NEN-EN 50380

(en)

Marking and documentation requirements for
Photovoltaic Modules

Technische beschrijving en naamplaatgegevens
voor foto-voltaïsche modules

Vervangt NEN-EN 50380:2003;
NEN-EN 50380:2016 Ontw.

ICS 27.160
september 2017

Als Nederlandse norm is aanvaard:
- EN 50380:2017,IDT

Nederlands Elektrotechnisch Comité
Normcommissie 361082 "Zonnenergiesystemen (NEC 82)"



THIS PUBLICATION IS COPYRIGHT/PROTECTED

DEZE PUBLICATIE IS AUTEURSRECHTELIJK BESCHERMD

Apart from exceptions provided by the law, nothing from this publication may be duplicated and/or published by means of photocopy, microfilm, storage in computer files or otherwise, which also applies to full or partial processing, without the written consent of the Royal Netherlands Standardization Institute.

The Royal Netherlands Standardization Institute shall, with the exclusion of any other beneficiary, collect payments owed by third parties for duplication and/or act in and out of law, where this authority is not transferred or falls by right to the Reproduction Rights Foundation.

Auteursrecht voorbehouden. Behoudens uitzondering door de wet gesteld mag zonder schriftelijke toestemming van het Koninklijk Nederlands Normalisatie-instituut niets uit deze uitgave worden verveelvoudigd en/of openbaar gemaakt door middel van fotokopie, microfilm, opslag in computerbestanden of anderszins, hetgeen ook van toepassing is op gehele of gedeeltelijke bewerking.

Het Koninklijk Nederlands Normalisatie-instituut is met uitsluiting van ieder ander gerechtigd de door derden verschuldigde vergoedingen voor verveelvoudiging te innen en/of daartoe in en buiten rechte op te treden, voor zover deze bevoegdheid niet is overgedragen c.q. rechtens toekomt aan de Stichting Reprorecht.

Although the utmost care has been taken with this publication, errors and omissions cannot be entirely excluded. The Royal Netherlands Standardization Institute and/or the members of the committees therefore accept no liability, not even for direct or indirect damage, occurring due to or in relation with the application of publications issued by the Royal Netherlands Standardization Institute.

Hoewel bij deze uitgave de uiterste zorg is nagestreefd, kunnen fouten en onvolledigheden niet geheel worden uitgesloten. Het Koninklijk Nederlands Normalisatie-instituut en/of de leden van de commissies aanvaarden derhalve geen enkele aansprakelijkheid, ook niet voor directe of indirecte schade, ontstaan door of verband houdend met toepassing van door het Koninklijk Nederlands Normalisatie-instituut gepubliceerde uitgaven.

English Version

Marking and documentation requirements for Photovoltaic Modules

Exigences de marquage et de documentation des modules photovoltaïques

Datenblatt- und Typenschildangaben von Photovoltaik-Modulen

This European Standard was approved by CENELEC on 2017-07-17. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for giving this European Standard the status of a national standard without any alteration.

Up-to-date lists and bibliographical references concerning such national standards may be obtained on application to the CEN-CENELEC Management Centre or to any CENELEC member.

This European Standard exists in three official versions (English, French, German). A version in any other language made by translation under the responsibility of a CENELEC member into its own language and notified to the CEN-CENELEC Management Centre has the same status as the official versions.

CENELEC members are the national electrotechnical committees of Austria, Belgium, Bulgaria, Croatia, Cyprus, the Czech Republic, Denmark, Estonia, Finland, Former Yugoslav Republic of Macedonia, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Latvia, Lithuania, Luxembourg, Malta, the Netherlands, Norway, Poland, Portugal, Romania, Serbia, Slovakia, Slovenia, Spain, Sweden, Switzerland, Turkey and the United Kingdom.



European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

CEN-CENELEC Management Centre: Avenue Marnix 17, B-1000 Brussels

Contents

	Page
European foreword	3
1 Scope	4
2 Normative references	4
3 Terms and definitions	5
4 Documentation information	6
4.1 General	6
4.2 Documentation language	6
4.3 Mandatory information	7
4.3.1 General	7
4.3.2 Electrical, including wiring, information	7
4.3.3 Mechanical information	8
4.3.4 Installation information	9
4.3.5 Certificates	9
4.3.6 Other information	9
4.4 Best practice information	9
4.4.1 Electrical, including wiring, information	9
4.4.2 Mechanical information	9
4.4.3 Installation information — Constructive characteristics	9
4.4.4 Certificates	10
4.4.5 Other information	10
5 Marking information	10
5.1 General	10
5.2 Mandatory information	10
5.2.1 General	10
5.2.2 Module identification	11
5.2.3 Electrical information	11
5.3 Best practice information	12
Annex A (informative) Determination of limited reverse current $I_{r,lim}$ carrying capacity	13
Annex B (informative) Verification procedure of electrical characteristics of PV modules	15
B.1 General	15
B.2 Initial determination (e.g. by manufacturer)	15
B.3 Verification by third party	15
B.4 Measurement procedure	16
Annex C (informative) Electrical characteristics for PV power plant design	18
C.1 Electrical characteristics for energy yield evaluation	18
C.2 Temperature corrections	18
C.3 Insulation properties under different environmental parameters	19
C.4 Capacitance of PV module	19
Bibliography	20

European foreword

This document (EN 50380:2017) has been prepared by CLC/TC 82 "Solar photovoltaic energy systems".

The following dates are fixed:

- latest date by which this document has to be implemented at national level by publication of an identical national standard or by endorsement (dop) 2018-07-17
- latest date by which the national standards conflicting with this document have to be withdrawn (dow) 2020-07-17

This document supersedes EN 50380:2003.

Attention is drawn to the possibility that some of the elements of this document may be the subject of patent rights. CENELEC [and/or CEN] shall not be held responsible for identifying any or all such patent rights.

Copyright
Preview

EN 50380:2017 (E)**1 Scope**

This European Standard describes marking, including nameplate and documentation requirements for non-concentrating photovoltaic modules.

This European Standard provides mandatory information that needs to be included in the product documentation or affixed to the product to ensure safe and proper use. Best practices are included in this document giving guidance on additional information, for example module's performance at different irradiance levels.

Markings, including nameplates, are permanently affixed information on the PV modules, which indelibly states the rating and other information as required by the relevant standard for safe use and maintenance. While, documentation information is a technical description separate from the photovoltaic module.

This European Standard is based on IEC and EN standards defining marking, nameplate and documentation requirements for PV modules.

2 Normative references

The following documents, in whole or in part, are normatively referenced in this document and are indispensable for its application. For dated references, only the edition cited applies. For undated references, the latest edition of the referenced document (including any amendments) applies.

EN 13501-1, *Fire classification of construction products and building elements - Part 1: Classification using data from reaction to fire tests*

EN 45011, *General requirements for bodies operating product certification systems (ISO/IEC Guide 65)*

EN 50618, *Electric cables for photovoltaic systems*

EN 60529, *Degrees of protection provided by enclosures (IP Code) (IEC 60529)*

EN 60904-10, *Photovoltaic devices - Part 10: Methods of linearity measurement (IEC 60904-10)*

prEN 61730-1:2015, *Photovoltaic (PV) module safety qualification - Part 1: Requirements for construction (IEC/CDV 61730-1:2015)*

EN 61730-2, *Photovoltaic (PV) module safety qualification - Part 2: Requirements for testing (IEC 61730-2)*

CLC/TS 61836, *Solar photovoltaic energy systems - Terms, definitions and symbols (IEC/TS 61836)*

EN 62790, *Junction boxes for photovoltaic modules - Safety requirements and tests (IEC 62790)*

EN 62852, *Connectors for DC-application in photovoltaic systems - Safety requirements and tests (IEC 62852)*

IEC 60050, *International Electrotechnical Vocabulary*

IEC 61215 (all parts), *Terrestrial Photovoltaic (PV) Modules – Design Qualification and Type Approval*

3 Terms and definitions

For the purposes of this document, the terms and definitions given in CLC/TS 61836, IEC 60050 and the following apply.

3.1

documentation

information provided by the manufacturer to allow satisfactory understanding, installation and safe use of the module

Note 1 to entry: Typically documentation is provided by manufacturer as user manual and data-sheet.

3.2

marking

permanently affixed information on an electric device, herein the PV module, which indelibly states the rating and other information as required by the relevant standard for safe use and maintenance

3.3

standard test conditions

STC

1 000 W/m², 25 °C, AM 1.5G (EN 60904-3)

Note 1 to entry: As defined in CLC/TS 61836.

3.4

nominal module operating temperature

NMOT

equilibrium mean photovoltaic cell junction temperature within an open-rack mounted module operating near peak power in the following standard reference environment (SRE)

Note 1 to entry: Determination procedure is explained in detail in MQT 05 of IEC 61215-2 and EN 61853-2.

- tilt angle: 37,5° ± 1,5° from the horizontal;
- total irradiance: 800 W/m²;
- ambient temperature: 20 °C;
- wind speed: 1 m/s;
- electrical load: A resistive load sized or maximum power point tracking (mppt) device such that the module will operate near maximum power point.

3.5

limited reverse current

I_R

current carrying capacity which gives the maximal current for operation of photovoltaic module at a working voltage $V \geq V_{oc}$ without permanent damages of the photovoltaic module

Note 1 to entry: For working voltages higher than open circuit voltage module, the current changes its algebraic sign (math. ±). This current is therefore a reverse current to the photovoltaic module.

3.6

nameplate

plate, permanently affixed on an electric device, which indelibly states the rating and other information as required by the relevant standard

[SOURCE: IEC 151-16-12]

EN 50380:2017 (E)**3.7****rated production tolerances**

value specified by the manufacturer that characterize the normal production tolerances at STC

Note 1 to entry: This is not the binning into power classes.

3.8**stabilized parameters**

electrical parameters that characterize the device in its stabilized state where it is usually operated

Note 1 to entry: For stabilization procedure and requirements see MQT 19 of IEC 61215-2. Stabilization can be achieved by light exposure or other validated method per IEC 61215-2.

3.9**initial parameters**

electrical parameters that characterize the device in its initial state directly after production

3.10**electrical characteristics**

P_{mpp} Power at maximum power point

P_{max} Maximum power at STC condition

V_{oc} Open circuit voltage at STC condition

I_{sc} Short circuit current at STC condition

V_{Pmax} Voltage at maximum power point at STC condition

I_{Pmax} Current at maximum power point at STC condition

V_{sys} Maximum system voltage

OCP_{max} Maximum overcurrent protection rating

3.11**rated current of overcurrent protection (OCP) device**

current rating of fuse or circuit breaker according to EN 60269-6

4 Documentation information**4.1 General**

Modules shall be supplied with documentation describing the methods of electrical and mechanical installation as well as the electrical ratings of the module. The documentation shall state the Class under which the PV module was qualified and any specific limitations required for that Class. The documentation shall state the environmental conditions to which the module has been qualified. It shall be ensured that appropriate documentation for safe installation, use, and maintenance are available to installers and operators.

The documentation of a PV module typically consists of a user manual and a data-sheet. The user manual/general documentation shall contain all information to comply with national legal product requirements. Extra requirements may apply. Summarized information in addition to the user manual is typically stated in a data-sheet but could also be directly part of the user manual.

For identical PV modules it is considered to be sufficient that one set of documentation is supplied with the PV module shipping unit.

International symbols shall be used where applicable.

4.2 Documentation language

Documentation required by this standard shall be written in an official language of the country in which the PV module is installed.

4.3 Mandatory information

4.3.1 General

This subclause lists the mandatory information to be provided for PV modules according to this standard.

4.3.2 Electrical, including wiring, information

The documentation shall contain the following electrical information:

- a) polarity of terminals or leads;
- b) "Maximum system voltage" or V_{sys} ;
- c) Maximum overcurrent protection (OCP) rating

Overcurrent protection devices with a 1hr, 1,35 I_R overload rating, where I_R is the rated value of the overcurrent protection device, are recommended.

NOTE Compliance can be checked according to EN 61730-2 MST 26. I_R -rating can be determined using procedure in Annex A.

- d) Class of protection against electrical shock, in accordance with EN 61730-1 (see further details in 5.2.3 f))

The following electrical data shall be shown as relative to standard test conditions (1 000 W/m², 25 °C, AM 1,5G according to CLC/TS 61836) and after stabilization. Manufacturer's stated rated production tolerance shall be given also under standard test conditions (STC).

- e) "Voltage at open-circuit" or " V_{oc} " including rated production tolerance
- f) "Voltage at maximum power point" or " V_{Pmax} " including rated production tolerance
- g) "Current at maximum power point"; or " I_{Pmax} " including rated production tolerance
- h) "PV module maximum power" or " P_{max} " including rated production tolerance
- i) "Current at short-circuit"; or " I_{sc} " including rated production tolerance

Electrical values after stabilization according to the IEC 61215 series shall be verifiable and within the specified rated production tolerances and uncertainties. A procedure is given in Annex B

NOTE 1 Example: $P_{\text{max}} = 250,0 \text{ W}$, rated production tolerance 3 %, binning + 5 W / - 0 W. That means that modules from 250,0 W to 254,9 W are sorted in one bin, rated $P_{\text{max}} = 250,0 \text{ W}$. Tolerance of 3 % results on deviations from 250,0 W from 242,5 W to 257,5 W.

If initial values differ by more than the manufacturer's stated production tolerances from stabilized values this shall be stated separately.

At the example of an a-Si type module with an initial degradation of 20 % and a rated production tolerance of 5 %, I_{sc} and V_{oc} have to be stated as initial and stabilized parameters.

If output of module (I_{sc} , V_{oc} and P_{max}) is site or mounting means dependent (e.g. due to back side illumination of bifacial cells) variability and maximal output (I_{sc} , V_{oc} and P_{max}) shall be stated.

- j) Relative temperature coefficients in [%/K] for I_{sc} , P_{max} and V_{oc} at STC

NOTE 2 The values for I_{MPP} and V_{MPP} can be provided.

- k) State if temperature coefficients are linear. In cases of nonlinear temperature coefficients according to EN 60904-10 further information regarding temperature coefficients shall be provided.

Bestelformulier

NEN

Stuur naar:

NEN Standards Products & Services
t.a.v. afdeling Klantenservice
Antwoordnummer 10214
2600 WB Delft

NEN Standards Products & Services

Postbus 5059
2600 GB Delft

Vlinderweg 6
2623 AX Delft

T (015) 2 690 390
F (015) 2 690 271

www.nen.nl/normshop

Ja, ik bestel

__ ex. NEN-EN 50380:2017 en Technische beschrijving en
naamplaatgegevens voor foto-voltaïsche modules

€ 50.04

**Wilt u deze norm in PDF-formaat? Deze bestelt u eenvoudig via
www.nen.nl/normshop**

Gratis e-mailnieuwsbrieven

Wilt u op de hoogte blijven van de laatste ontwikkelingen op het gebied van normen, normalisatie en regelgeving? Neem dan een gratis abonnement op een van onze e-mailnieuwsbrieven. www.nen.nl/nieuwsbrieven

Retourneren

Fax: (015) 2 690 271
E-mail: klantenservice@nen.nl
Post: NEN Standards Products & Services,
t.a.v. afdeling Klantenservice
Antwoordnummer 10214,
2600 WB Delft
(geen postzegel nodig).

Gegevens

Bedrijf / Instelling

T.a.v. O M O V

E-mail

Klantnummer NEN

Uw ordernummer BTW nummer

Postbus / Adres

Postcode Plaats

Telefoon Fax

Factuuradres (indien dit afwijkt van bovenstaand adres)

Postbus / Adres

Postcode Plaats

Datum Handtekening

Voorwaarden

- De prijzen zijn geldig tot 31 december 2016, tenzij anders aangegeven.
- Alle prijzen zijn excl. btw, verzend- en handelingskosten en onder voorbehoud bij o.m. ISO- en IEC-normen.
- Bestelt u via de normshop een pdf, dan betaalt u geen handeling en verzendkosten.
- Meer informatie: telefoon (015) 2 690 391, dagelijks van 8.30 tot 17.00 uur.
- Wijzigingen en typfouten in teksten en prijsinformatie voorbehouden.
- U kunt onze algemene voorwaarden terugvinden op: www.nen.nl/leveringsvoorwaarden.