

HARMONIZATION DOCUMENT

HD 516 S2/A1

DOCUMENT D'HARMONISATION

HARMONISIERUNGSDOKUMENT

April 2003

ICS 29.060.20

English version

Guide to use of low voltage harmonized cables

Guide d'emploi des câbles harmonisés
à basse tension

Leitfaden für die Verwendung
harmonisierter Niederspannungs-
starkstromleitungen

This amendment A1 modifies the Harmonization Document HD 516 S2:1997; it was approved by CENELEC on 2003-02-01. CENELEC members are bound to comply with the CEN/CENELEC Internal Regulations which stipulate the conditions for implementation of this amendment on a national level.

Up-to-date lists and bibliographical references concerning such national implementation may be obtained on application to the Central Secretariat or to any CENELEC member.

This amendment exists in three official versions (English, French, German).

CENELEC members are the national electrotechnical committees of Austria, Belgium, Czech Republic, Denmark, Finland, France, Germany, Greece, Hungary, Iceland, Ireland, Italy, Luxembourg, Malta, Netherlands, Norway, Portugal, Slovakia, Spain, Sweden, Switzerland and United Kingdom.

CENELEC

European Committee for Electrotechnical Standardization
Comité Européen de Normalisation Electrotechnique
Europäisches Komitee für Elektrotechnische Normung

Central Secretariat: rue de Stassart 35, B - 1050 Brussels

© 2003 CENELEC - All rights of exploitation in any form and by any means reserved worldwide for CENELEC members.

Ref. No. HD 516 S2:1997/A1:2003 E

Dit document mag slechts op een stand-alone PC worden geïnstalleerd. Gebruik op een netwerk is alleen toestaan als een aanvullende licentieovereenkomst voor netwerkgebruik met NEN is afgesloten. This document may only be used on a stand-alone PC. Use in a network is only permitted when a supplementary license agreement for us in a network with NEN has been concluded.

Foreword

This amendment was prepared by the Technical Committee CENELEC TC 20, Electric cables, and agreed at the Paris meeting (May 2001) to go forward to the Unique Acceptance Procedure.

This amendment has been prepared within the regular maintenance programme.

The text of the draft was submitted to the Unique Acceptance Procedure and was approved by CENELEC as amendment A1 to HD 516 S2:1997 on 2003-02-01.

The following dates were fixed:

- latest date by which the existence of the amendment has to be announced at national level (doa) 2003-08-01
- latest date by which the amendment has to be implemented at national level by publication of a harmonised national standard or by endorsement (dop) 2004-02-01
- latest date by which the national standards conflicting with the amendment have to be withdrawn (dow) 2005-02-01

Copyright
Preview

Subclause 4.2.4

In the 2nd indent of the examples **replace** “overcurrent” by “current”.

Subclause 4.4.5

Add the following paragraph at the end of the subclause:

For the particular case of welding cables, either for industrial arc welding or for hobby welding, the use of PVC covered cables should not be permitted. Only those types harmonised in HD 22/6, which are cross-linked rubber types, are recommended. These cross-linked types meet relevant requirements relating to safety, including a special test for resistance to the hot particles that are commonly generated during welding.

Table 1B

Add a new column for HD 22.3, Clause 4, H05SS-K.

As for H05SJ-K, Clause 2.

Supplement to Table 1B

Add the following information for Part 3, Clause 4, H05SS-K

1	2	3
Part No.	Recommended use	Comments
Part 3 Clause 4 (H05SS-K) Heat resistant silicone rubber sheathed single core cables	At high temperature; for fixed installation in and on lamps in appliances, especially when the requirement is to have a cable with both insulation and sheath.	This cable may be damaged by contact with sharp edges and by abrasion. Care should be taken to avoid this in installation and in use.

Table 2A

Under the first column for HD 21.5:

- **amend** the Clause numbers to read “2”
- **delete** the sub-column for conductor type “H”

Supplement to Table 2A

Delete the entry for Part 5, Clause 3, flat non-sheathed cord, H03VH-H.

Amend the entries for HD 21.5, Clause 5 by adding in column 2 (Recommended use) the additional sentence:

“Also, excluding flat cables, for hand-held inspection lamps.”

and by **amending** the final entry in column 3 to read:

“Unsuitable for permanent outdoor use, ……….”

Amend the entries for HD 21.13 such that the clause numbers in column 1 are respectively:

“Clause 3 (not 2) for H05VV5-F, and Clause 4 (not 3) for H05VVC4V5-K”

Table 2B - Intended Usage of Rubber Flexible Cables or Cords

Delete the entries for HD 22.4, Clause 2, H03RT-F, and HD 22.14, Clause 4, H03RV4-H

Add new entries as below:

Standard	HD 22.14	HD 22.15		HD 22.16
Clause numbers	6	3	4	3/4
Designation	H03RT	H05SS(T)	H05SSD3(T)	H07RN8
Cross section shape	Circ	Circ	Circ	Circ
Conductor type	H	F	F	F
1. DUTY (1)				
1.1 Extra light	+	+	+	+
1.2 Light	+	+	+	+
1.3 Ordinary	+	+	+	+
1.4 Heavy	-	-	-	+
2. PRESENCE OF WATER				
2.1 Condition AD1 (2)	+	+	+	+
2.2 Condition AD2 (2)	+	+	+	+
2.3 Condition AD6 (2)	-	-	-	+
2.4 Condition AD8 (2) (up to 10m)	-	-	-	+
3. CORROSIVE OR POLLUTING SUBSTANCES				
3.1 Condition AF3 (2)	-	-	-	+
4. IMPACT				
4.1 Condition AG2 (2)	-	-	-	+
5. VIBRATIONS				
5.1 Condition AH3 (2)	-	-	-	+
6. FLORA				
6.1 Condition AK2 (2)	-	-	-	-
7. FAUNA				
7.1 Condition AL2 (2)	-	-	-	-
8. OUTDOOR USE(3)				
8.1 Temporary (5)	+	+	+	+
8.2 Permanent (5)	-	(8)	+	+
9. FREQUENT FLEXING	+	+	-	+
10. FREQUENT TORSION	+	+	-	+

Supplement to Table 2B

Delete the entry for Part 4, Clause 2, H03RT-F.

Amend the entries for HD 22.4, Clause 3, and HD 22.10 by adding in column 2 (Recommended use) the additional sentence:

“Also for hand-held inspection lamps.”

Amend the entry for HD 22.4, Clauses 5 and 6, by adding in column 2 (Recommended use) the additional sentences:

'Unsuitable for situations involving permanent immersion in water. Cables for such applications are specified in HD 22.16.'

Bestelformulier

Stuur naar:

NEN Standards Products & Services
t.a.v. afdeling Klantenservice
Antwoordnummer 10214
2600 WB Delft



NEN Standards Products & Services

Postbus 5059
2600 GB Delft

Vlinderweg 6
2623 AX Delft

T (015) 2 690 390
F (015) 2 690 271

www.nen.nl/normshop

Ja, ik bestel

__ ex. HD 516:1997/A1:2003 en Het gebruik van geharmoniseerde leidingen voor laagspanning € 52.00

Wilt u deze norm in PDF-formaat? Deze bestelt u eenvoudig via www.nen.nl/normshop

Gratis e-mailnieuwsbrieven

Wilt u op de hoogte blijven van de laatste ontwikkelingen op het gebied van normen, normalisatie en regelgeving? Neem dan een gratis abonnement op een van onze e-mailnieuwsbrieven. www.nen.nl/nieuwsbrieven

Gegevens

Bedrijf / Instelling _____

T.a.v. _____ O M O V

E-mail _____

Klantnummer NEN _____

Uw ordernummer _____ BTW nummer _____

Postbus / Adres _____

Postcode _____ Plaats _____

Telefoon _____ Fax _____

Factuuradres (indien dit afwijkt van bovenstaand adres)

Postbus / Adres _____

Postcode _____ Plaats _____

Datum _____ Handtekening _____

Retourneren

Fax: 015 2 690 271

E-mail: klantenservice@nen.nl

Post: NEN Standards Products & Services,

t.a.v. afdeling Klantenservice
Antwoordnummer 10214,
2600 WB Delft

(geen postzegel nodig).

Voorwaarden

- De prijzen zijn geldig tot 31 december 2018, tenzij anders aangegeven.
- Alle prijzen zijn excl. btw, verzend- en handelingskosten en onder voorbehoud bij o.m. ISO- en IEC-normen.
- Bestelt u via de normshop een pdf, dan betaalt u geen handeling en verzendkosten.
- Meer informatie: telefoon 015 2 690 391, dagelijks van 8.30 tot 17.00 uur.
- Wijzigingen en typfouten in teksten en prijsinformatie voorbehouden.
- U kunt onze algemene voorwaarden terugvinden op: www.nen.nl/leveringsvoorwaarden.